

SKZ - Testing GmbH awards the following company

aquatherm GmbH
Biggen 5
DE-57439 Attendorn

Production site: aquatherm GmbH, DE-57439 Attendorn

the right to use the **SKZ**-mark



A 644

for the following plastic products

Fibre multilayer pipes made of PP-RCT/PP-RCT GF/PP-RCT, SDR 7.4 and 9
Group 1 ($\leq \varnothing 63$ mm), Group 2 ($\varnothing 75 - 160$ mm), Group 3 (> 160 mm)

Dimensionen		Application class	
		1	2
SDR 7.4	20 x 2.8 mm, 25 x 3.5 mm	8 bar	8 bar
SDR 9	32 x 3.6 mm, 40 x 4.5 mm, 50 x 5.6 mm, 63 x 7.1 mm, 75 x 8.4 mm, 90 x 10.1 mm, 110 x 12.3 mm, 125 x 14.0 mm, 160 x 17.9 mm, 200 x 22.4 mm 250 x 27.9 mm, 315 x 35.2mm	8 bar	8 bar

Trade name: green pipe SDR9 MF-RP
green pipe SDR 7,4 MF-RP

according to **SKZ**-Specification for Tests and Inspection **HR 3.28:2021-08**.

Users of the **SKZ**-mark are obliged to observe the required regulations for the production and testing of these products.

Date of initial certification: 1 October 2013

Date of expiry: 4 October 2028

Würzburg, 8 January 2026//



i.V. 
Dipl.-Ing. (FH) Katja Müller
Head of Certification Body

The original language of this certificate is German. In case of doubt, the German version is obligatory.

SKZ - Testing GmbH, Friedrich-Bergius-Ring 22, 97076 Würzburg, Germany | Tel. +49 931 4104-0, testing@skz.de, www.skz.de
The Certification Body of SKZ - Testing GmbH is accredited by DAkKS according to DIN EN ISO/IEC 17065:2013 under the number D-ZE-19033-01.

Die **SKZ - Testing GmbH** verleiht der Firma

aquatherm GmbH
Biggen 5
DE-57439 Attendorn

Produktionsstandort: *aquatherm GmbH, DE-57439 Attendorn*

das Recht zum Führen des **SKZ-Zeichens**



A 644

für nachstehende Kunststoffzeugnisse

Faserverbundrohre aus PP-RCT/PP-RCT GF/PP-RCT, SDR 7,4 und 9
Gruppe 1 ($\leq \varnothing 63$ mm), Gruppe 2 ($\varnothing 75 - 160$ mm), Gruppe 3 (> 160 mm)

Dimensionen		Anwendungsklasse	
		1	2
SDR 7,4	20 x 2,8 mm, 25 x 3,5 mm	8 bar	8 bar
SDR 9	32 x 3,6 mm, 40 x 4,5 mm, 50 x 5,6 mm, 63 x 7,1 mm, 75 x 8,4 mm, 90 x 10,1 mm, 110 x 12,3 mm, 125 x 14,0 mm, 160 x 17,9 mm, 200 x 22,4 mm, 250 x 27,9 mm, 315 x 35,2mm	8 bar	8 bar

Handelsname: *green pipe SDR9 MF-RP*
green pipe SDR 7,4 MF-RP

nach den **SKZ-Prüf- und Überwachungsbestimmungen HR 3.28:2021-08.**

Mit der Führung des **SKZ-Zeichens** ist die Verpflichtung verbunden, bei der Herstellung und Prüfung der Erzeugnisse die vorgeschriebenen Bestimmungen einzuhalten.

Erstzertifizierung: 1. Oktober 2013

Gültig bis: 4. Oktober 2028

Würzburg, 8. Januar 2026//



i.V. 

Dipl.-Ing. (FH) Katja Müller
 Leiterin der Zertifizierungsstelle